
Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Lake Shore Middle School	5/26/2021	85	61	24	N/A	N/A

** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
109.2-27	Rm 327 Front Facing	Sink	27.6
109.2-28	Rm 327 Back Facing	Sink	17.2
109.2-29	Rm 330	Sink	15.5
109.2-37	Rm 321	Sink	15.9
109.2-38	Rm 332 Back Wall Left Sink	Sink	72.3
109.2-40	Rm 332 Back Wall Left Middle Sink	Sink	38.0
109.2-41	Rm 332 Back Wall Right Middle Sink	Sink	34.8
109.2-44	Media Center	Sink	21.1
109.2-45	Rm 338	Sink	43.2
109.2-70	Aud. Back Room Main Sink	Sink	29.1
109.2-71	Aud. Girls Lav	Sink	34.0
109.2-72	Aud. Boys Lav	Sink	24.5
109.2-86	Girls Lav Near Gym	Sink	28.0
109.2-88	Boys Lav Near Gym	Sink	24.6
109.2-93	Kitchen Left Triple Sink	Sink	24.4
109.2-94	Kitchen Right Triple Sink	Sink	17.2
109.2-104	Faculty Lav Neat Café Right Women	Sink	30.0
109.2-106	Kitchen Staff Women's Lav Left Sink	Sink	25.0
109.2-107	Kitchen Staff Women's Lav Right Sink	Sink	30.0
109.2-108	Tech Room	Sink	17.9
109.2-137	Boys Pool Locker Room Bathroom	Sink	31.2
109.2-138	Laundry Room	Sink	28.2
109.2-140	Girls Pool Locker Room Left Sink	Sink	51.3
109.2-141	Girls Pool Locker Room Right Sink	Sink	57.9